

Buletin de analiza nr. 593C1 din data 08.07.2026

Informatii furnizate de beneficiar		Informatii furnizate de laborator	
Beneficiar	ASOCIATIA APA BAISOARA	Cod proba	593C1
Adresa	Muntele Baisorii,Nr.58	Data receptiei	08.07.2026 Ora: 08:48
Punct de prelevare	Muntele Baisora	Data executiei analizei	08.07.2026
Tipul probei	Apa potabila - Izvor	Monitorizare Audit ☐ Programe Nationale ☐ Monitorizare Operationala ☐ Contra Cost ☒ Actiuni Tematice ☐ Sesizari ☐	
Ambalaj / Volum	Recipient plastic - 1L		
Prelevat de	beneficiar		
Proces Verbal	-		
Data prelevarii	07.07.2026 Ora: 19:00		

Cerere analiza: C1-401 / 03.07.2026

Disp. incasare: LCST C1-401 / 03.07.2026

Nr Crt	Parametru	UM	Rezultat	Valoare admisa conform OG 7-2023 aprobata prin Legea 96-2024	Metoda
1	Amoniu	mg/l	0.058	0.5	PS-LCST 01, Ed.05, Rev.01 Metoda Merck Spectroquant 114752
2	Nitriti	mg/l	< 0.07	0.5	PS-LCST 01, Ed.05, Rev.01 Metoda Merck Spectroquant 114776
3	Nitrati	mg/l	9.23	50	PS-LCST 01, Ed.05, Rev.01 Metoda Merck Spectroquant 109713
4	Suma de calciu si magneziu (Duritate totala)	grd.Ger.	7.98	-	SR ISO 6059:2008 PS-LCST-02
5	pH	unitati pH	6.0 (20 °C)	6.5 - 9.5	SR EN ISO 10523:2012 PS-LCST-03
6	Fier	µg/l	13.77	200	PS-LCST 01, Ed.05, Rev.01 Metoda Merck Spectroquant 114761

Nota: Rezultatele se refera numai la proba analizata.
Reproducerea partiala a buletinului de analiza este interzisa
Beneficiarul isi asuma responsabilitatea pentru informatiile furnizate (de care laboratorul nu este responsabil)
< -sub limita de cuantificare a metodei

Autorizat

Coordonator Laborator
Chim. pr. Carmen Parau

Verificat

chim. Alina Pop

Semnata digital de catre: